Met One Instruments BAM-1020 PM_{2.5} FEM

David Gobeli, Ph.D.

Met One Instruments

dgobeli@metone.com

Agenda

- Background
- Test Protocol
- Test Results

Background


- US Regulations (40CFR § 53) revised in October, 2006
- No Coarse (PM_{10-2.5}) Standard
 - Very unexpected change of course
 - US network will be minimal (~75 sites total, probably far fewer with automatic monitors)
 - At least 5 years before issue is revisited.
 - 1987 PM₁₀ regulations reaffirmed
- Detailed designation procedures developed for automatic (Class III) PM_{2.5} monitors


New US Regulations 40 CFR § 53

- Expect PM monitoring sites currently using Federal Reference Method (FRM) samplers to be replaced with continuous monitors after PM_{2.5} FEM monitors become available.
- US-EPA is encouraging development of particulate speciation samplers for PM_{10-2.5} fraction

PM_{2.5} Comparability Test Protocol

- 5 Test Campaigns
 - 3 Winter
 - 2 Summer
- Triplicate BAM-1020 and Triplicate FRM
- Minimum 23 Valid Days of Data
 - 46 Valid Days for Winter/Summer Site
- Strict criteria for multiplicative (slope), additive (intercept) bias and precision







Allen Park, MI



Logan, UT



Bakersfield, CA




New Haven, CT



BAM-1020 PM_{2.5} FEM Status

- BAM-1020 successfully completed US-EPA PM_{2.5} FEM field campaigns at all sites
 - Logan UT (winter)
 - Bakersfield CA (winter and summer)
 - Allen Park, MI (winter)
 - New Haven, CT (summer)
- Designation application completed and submitted.

Logan, UT Winter



10/21/2007


14

Logan, UT Winter

Regression statistics		Slope ¹	Intercept ²	Correlation (r)
Statistics for this test site:		0.973	0.129	0.99751
Limits for	Upper:	1.100	2.000	
PM2.5 Class III	Lower:	0.900	-1.803	0.95000
Test Results (Pass/Fail):		PASS	PASS	PASS



Allen Park, MI Winter




Allen Park, MI Winter

Regression statistics		Slope	Intercept ²	Correlation (r)
Statistics for this test site:		0.940	-0.955	0.99275
Limits for	Upper:	1.100	2.000	
PM2.5 Class III	Lower:	0.900	-1.238	0.95000
Test Results (Pass/Fail):		PASS	PASS	PASS




Bakersfield, CA Winter and Summer




Bakersfield CA Winter and Summer

Regression statistics		Slope ¹	Intercept ²	Correlation (r)
Statistics for this test site:		0.970	-0.754	0.99678
Limits for	Upper:	1.100	2.000	
PM2.5 Class III	Lower:	0.900	-1.748	0.95000
Test Results (Pass/Fail):		PASS	PASS	PASS




New Haven, CT - Summer



New Haven, CT Summer

Regression statistics		Slope	Intercept ²	Correlation (r)
Statistics for this test site:		1.020	0.585	0.99765
Limits for	Upper:	1.100	1.586	
PM2.5 Class III	Lower:	0.900	-2.000	0.95000
Test Results (Pass/Fail):		PASS	PASS	PASS



Conclusions

- Slope/Intercept almost identical at each test site
 - No geographical influence
 - No seasonal influence
- Changes to BAM-1020 required to meet new designation rules are relatively modest
 - No increased complexity
- No site specific calibration factors

Conclusions (continued)

 BAM-1020 will likely be the first PM_{2.5} monitor to receive US-EPA designation as Class III FEM.

BAM-1020 FEM Specifications

Parameter	Performance Specification
Measurement Ranges	0-1,000 μg/m³ standard
Measurement Cycle	1 hour standard, others available
Sampling period per measurement cycle	40-50 minutes user selectable depending on counting period per cycle
Counting period per measurement cycle	4, 6 or 8 minutes
Lower Limit of Detection (2 σ) 1 hour	< 3.0 μg/m ³
Lower Limit of Detection (2 σ) 24-hours	< 0.6 μg/m³
Root mean square (RMS) error (1-hour)	< 1.5 μg/m³
Root mean square (RMS) error (24-hours)	< 0.3 μg/m³
Source Composition and Activity	¹⁴ C < 100 μCi