# **TEOM/FDMS in NH** QA/Validation Methods & Issues

By Jessica Sheldon May 17, 2006





#### Weekly

- Time Check/Adjustment
- Flow Audit (skip if raining do others?)
- Filter Check (change if near 90%)
  - If FDMS, 47mm filter changed at same time

### Monthly

- Same as above, PLUS...
- Temp/Pres Check
- Part Maintenance (cleaning bonnet, cyclone)

#### Other (in the field)

- Pump Test (every 3 months)
- In-line Filter Changes
  - Bypass (every 6 months)
  - Main (every year)
- Leak Check
  - After FDMS 47mm filter change (risk of leak if not filter cartridge/holder not properly installed)
  - If troubleshooting
- Software Calibration of flow adjustment factors (if flow audit fails or near failing)

#### Other (in the lab)

- Pump Rebuilds
  - As needed (when pump approaches -20 inHg)
- Dryer Cleaning
  - So far, done only when needed (ex. dryer status)
  - Planning to make this routine to <u>prevent</u> dryer failures
    Every year (ex. just before Annual Maintenance)

#### Annual (everything else!)

- Flow Audit
- Temp/Pres Check/Calibration
- CPU Battery Test
- Analog Board Calibration
- KO Confirmation
- Mass Transducer Hardware Calibration
- Leak Check

## Data Downloads

- **RPComm** set up remotely to all sites
- Regularly download data at 5-min (1400AB) and 6-min (FDMS) resolution
- Downloaded parameters vary by needs, but try to consistently record...
  - Mass Conc
  - Status
  - Dryer-Out RH/Temp or Dew Point, where applicable
- Input data into spreadsheets every few days
  - Allows visual of recent data to catch problems
  - Plotted data aids in validation

### Data Validation

#### Invalidate if:

- Hourly average < -4.0</p>
  - Negative values tend to occur during/after rain events
- When <u>status</u> code present or <u>channel downed</u> (QA)
  - Use downloaded data to determine interval of affected data, identify captured status codes, etc....
  - When in doubt, invalidate all flagged hours
- Flow audit failed
  - Invalidate all hours between previous and subsequent passing flow audits
- Filter Loading <u>>99</u>

### Data Validation

#### Consider Invalidation if:

- Data is highly erratic or isolated spike/dip occurs
  - Refer to downloaded data for greater insight
  - Compare to other sites, look for similar patterns
  - Identify potential effects due to weather (raining?, sudden shift in wind direction or speed?)
- Dilemma (more on this later):
  - What to do about positive reference mass in FDMS units?
    - Is there a cutoff value, such that hours with high reference mass should be invalidated?

## Sensitivity to Temperature

 At about 4pm, April 13<sup>th</sup>, the door of the enclosure around the TEOM pump at Manchester was closed

(just to drown noise while doing work unrelated to the TEOM)

- Late that night, a temperature status was triggered due to an elevated case temp
- When the pump door was re-opened in the morning, the temp status disappeared

### "Normal" Oscillations?



- Data downloaded at 5-minute interval shows rapid up/down pattern, but not all the time
- Is this inherent to the instrument calculations, or does it indicate a problem, changing conditions?
- Have other states seen this pattern in their data?

## Up/Down...Up/Down...



### Yet Another Variation: "Take 1"



- Lebanon had previously had an FDMS, but this was replaced with the 1400AB in mid-March
- Almost immediately, starting seeing pattern of peaks and troughs cycling on an ~hourly basis
- Seemed to have diurnal pattern
  - Either stopped or was masked during daytime hours

## Yikes!

- First thought: loose filter (can lead to extreme ranges in values)
- Multiple troubleshooting attempts, but believe problem was: <u>loose latch</u> on mass transducer!
  - check that screw stays tight

(loosens with repeated opening/closing)



### Yet Another Variation: "Take 2"



- After the episode with the loose filter, nighttime pattern seemed to have disappeared – was it also related to a loosening latch?
- Now, different, daytime pattern frequently observed (above)
- OR sometimes sudden, isolated dips (below)
- Also, clock constantly falling behind, despite calibrations
- Cause(s) unknown; investigating possible voltage issues



### Positive Reference Mass (FDMS)

- Our seacoast site, as an FDMS, always ran higher than others
- 8500 unit was replaced with a new one (initially just for dryer cleaning, but ended up staying at the site)
- Suddenly, site concentrations seemed lower
- When started recording reference mass, saw that the reference mass was very often positive



### Positive Reference Mass (FDMS)

- No indication of a problem with the unit
  - No status, all tests passed, including leak test
- Pattern continued after dryer cleaned
- Recently, reinstalled original 8500 unit
- Now, site runs high again, and reference mass is almost always negative!

